

OSWEGO COUNTY PUBLIC SAFETY CENTER

WIRE/CONDUIT RUNS

(See Drawing 10163001 for Conduit Riser Diagram)

RUN #	QTY	WIRE TYPE	CONDUIT	FROM LOCATION	TO LOCATION	PURPOSE	COMMENTS
01	3	#12 THHN STR	3/4"	B218	CENTRAL CONTROL	UPS POWER	
02	2	WP-4246	3/4"	RM A261: SER-A	GENERAL POPULATION	TS-4	
	1	WP-373				TS-4 I/C MASTER	
03	2	WP-4246	3/4"	RM A261: SER-A	FEMALE POPULATION	TS-6	
	1	WP-373				TS-6 I/C MASTER	
04	2	WP-4246	3/4"	RM A261: SER-A	INTAKE POPULATION	TS-5	
	1	WP-373				TS-5 I/C MASTER	
05	2	WP-4246	3/4"	RM B218: SER-B1	RM A261: SER-A	TS NETWORK	
	1	WP-4246				CARD ACCESS NETWORK	NOTE 1
06	2	WP-4246	3/4"	RM B218: SER-B1	SPECIAL MANAGEMENT HOUSING	TS-3	
	1	WP-373				TS-3 I/C MASTER	
07	2	WP-4246	3/4"	RM B218: SER-B1	MAXIMUM SECURITY	TS-8	
	1	WP-373				TS-8 I/C MASTER	
08	2	WP-4246	3/4"	RM B218: SER-B1	CENTRAL CONTROL	TS-1	
	1	WP-4246				TS-11/C MASTER (IP)	
	2	WP-4246	TS-2				
	1	WP-4246	TS-2 I/C MASTER (IP)				
09	1	WP-4246	3/4"	RM B218: SER-B1	SEC-E	TS NETWORK	NOTE 3
	1	WP-4246				UPS ALARM	
10	2	WP-4246	3/4"	RM B218: SER-B1	RM C161: SER-C	TS NETWORK	
	2	WP-4246				CCTV NETWORK	
	1	WP-4246				CARD ACCESS NETWORK	
11	2	WP-4246	3/4"	RM C161: SER-C	BOOKING	TS-7	
	1	WP-4246				TS-7 I/C MASTER (IP)	
12	1	WP-4246	3/4"	RM C161: SEC-C	CORRECTIONS SUPERVISOR'S OFFICE	DIGITAL VIDEO WORKSTATION	
13	1	WP-4246	3/4"	RM C161: SEC-C	DISPATCH OFFICE	DIGITAL VIDEO WORKSTATION	
	1	WP-4246	3/4"			CARD ACCESS WORKSTATION	
14	1	WP-4246	3/4"	RM B218: SER-B1	ADMIN'S OFFICE	DIGITAL VIDEO WORKSTATION	
	1	WP-4246	3/4"			CARD ACCESS WORKSTATION	
15	1	WP-4246	3/4"	RM C161: SER-C	CRTS-CA	CARD ACCESS NETWORK	
16	1	WP-4246	3/4"	RM C161: SER-C	RM EVID-CA: SER-D	CARD ACCESS NETWORK	
	1	WP-4246				UPS ALARM	
17	1	WP-4246	3/4"	RM EVID-CA: SER-D	C308	CARD ACCESS WORKSTATION	
18	1	WP-3270	3/4"	RM B218	CARD READER 007	CARD READER	NOTE 2
19	1	WP-3270	3/4"	CRTS-CA	CARD READER 003	CARD READER	NOTE 2
20	1	WP-3270	3/4"	EVID-CA	CARD READER 014	CARD READER	NOTE 2
21	1	WP-4246	3/4"	RM A261: SER-A	RM A261: SEC-A	TS NETWORK	
22	1	WP-4246	3/4"	RM B218: SER-B1	RM B218: SER-B2	TS NETWORK	
	1	WP-4246				CCTV NETWORK	
23	1	WP-4246	3/4"	RM B218: SER-B2	RM B218: SEC-B	TS NETWORK	
24	1	WP-4246	3/4"	RM C161: SER-C	RM C161: SEC-C	TS NETWORK	

NOTES:

1. The cable run to the card access system in Room A261 extends to the controllers mounted on the wall; leave enough cable tailed out to reach the controller location.
2. Cable run from the card reader station back to the card access controller in the associated equipment room
3. SEC-E is located in the electrical room behind the "Rec Office" (where the lighting control for the 'B' area is located).