



## OSWEGO COUNTY PURCHASING DEPARTMENT

County Office Building • 46 East Bridge Street • Oswego, NY 13126  
Phone (315) 349-8234 Fax (315) 349-8308 Fred@oswegocounty.com

**Fred Maxon**  
Purchasing Director

**Gail VanLinder**  
Purchasing Clerk

**Mary Watson**  
Purchasing Clerk

August 12, 2009

### **Addendum #1:** Bid Package, 28-09 Construction of Senior Nutrition Site

**RE: ADDENDUM NO. 1 TO BIDDING DOCUMENTS DATED: AUGUST 3, 2009.**

This addendum shall become part of the bidding contract documents and shall modify the documents as indicated. Failure of any bidder to acknowledge receipt of this addendum on the bid form may result in the rejection of the bid.

Modifications to the Contract Documents as follows:

Project Address: 5871 Scenic Ave, Mexico New York.

#### **Front End Section:**

##### **Item No. 1:**

There are 2 different Invitation to Bid Forms. Note: Correct Bid Receipt date is August 18<sup>th</sup>.

Please delete all reference to the 2<sup>nd</sup> Bid Form (references Bid Receipt date of August 21 which is incorrect).

This form precedes the "Instruction to Bidders" Page 2;

Page 1 of "Instruction to Bidders" is missing.

Insert attached Page No 1 of the "Instruction to Bidders".

##### **Item No. 2:**

Form of Proposal Page 4:

1. Total Bid: Delete reference to ... "with taxes".  
Project is Tax exempt so any reference to this is not applicable.

##### **Item No. 3:**

Form of Proposal Page 8:

1. Delete All Reference to "Non-Collusive Bidding Certification" included in Specifications.
2. Refer to attached Owner supplied "Non-Collusive Bidding Certification Form" to be used instead.
3. Refer to attached Owner supplied "RESOLUTION FOR CORPORATIONS ONLY".

##### **Item No. 4:**

Construction Walk-Thru of the Building is scheduled to be Open to the Contractors:

1. Wednesday August 12, 2009. Between 9:00 am to 1:00 Pm

Item No. 5:

Added Document:

Refer to Owner supplied "Utilization of Section 3 Residents and Businesses".

1. Pages 1 thru 4.

Item No. 6:

Bid Bond:

1. Bid Bonds are to be made out to OCO (Oswego County Opportunities, Inc.)

Item No. 7:

All Bidders shall:

1. Notify Oswego County Purchasing Department and provide e-mail address to ensure that they will be notified of all Addendums.
2. Notify Zausmer Frisch no later than 5:00 PM August 15 to verify Addendums issued to date.

**Drawings:**

Item No. 1:

Kitchen Equipment Drawings: EQ- Series

1. Does not incorporate the latest background architectural drawings with the revisions to the Electrical Room with the Boiler locations.
  - a. This does not affect Kitchen Equipment Pricing.
2. Equipment No. 34 to be shifted to the left and No. 36 relocated to the right to allow for relocation of unit No. 34.

**Specs / Drawings:**

Item No. 1:

Electrical:

Electrical Contractor to provide and install all electrical devices/connections, etc for all Kitchen Equipment items as scheduled. Refer to Cut Sheets for power requirements.

On Sheet E-2, Electrical Power Performance Plan, insert:

Notes:

1. Electrical appliances and devices which are not located on a full height wall allowing for concealed electrical distribution to serve the appliance shall be served from a power pole with the branch circuit originating from above. Power pole shall be hubbell aluminum service poles or equal. Poles shall be securely anchored at the ceiling and at the floor. Provide duplex receptacle at a height as required of the appliance.
2. Cart Storage Area:  
In eighteen (18) locations where the heated/insulated transport cases (Item 38) are to be stored, Contractor shall furnish and install a ceiling mounted junction box with a duplex receptacle. At each location Contractor shall furnish and install two (2) electrical whips from the ceiling mounted duplex receptacle with enough free length to reach the connection at Item 38. Each whip shall consist of a 2 pole, 3 wire grounding twist lock device, insulgrip connector body, Hubbell HBL2434, or equal. The whip shall terminate with a 2 pole, 3 wire grounding twist lock device, insulgrip plug, hubbell model hbl2341, or equal.

Item No. 2:

Electrical:

Electrical Contractor to provide and install all electrical devices/connections, etc and data for ceiling mounted screen at Conference Area Room 104.

1. Location to be coordinated with Architect.
2. Screen to be selected and provided by the Owner.

**Addendum Sketches:**

Item No. 1:

1. Refer to attached Addendum Sketch ADD-1A.
  - a. Corrected dimension string at Front Windows.
2. Refer to attached Addendum Sketch ADD-2A.
  - a. Corrected Equipment locations for items 34 and 36.
  - b. Identified area receiving (9) quad ceiling drops w/ spiral cords.
  - c. Added note about additional power requirements for Kitchen Equipment.
3. Refer to attached Addendum Sketch ADD-1S:
  - a. Added slab infill detail at missing areas along back of building.
  - b. Coordinate with Sheet D-101 and field conditions for locations.
4. Steel girt infills at back wall to match existing material profile, ga. and fastening requirements.
  - a. Coordinate with Sheet D-101 and field conditions for locations.

END OF ADDENDUM

Fred M. Maxon  
Purchasing Director